

---

## ADDENDUM NUMBER 2 TO THE BID DOCUMENTS

Date: **May 23, 2018**

### MATTHEWS-MINT HILL RD SIDEWALK PROJECT

**A. This Addendum shall be considered part of the bid documents for the above-mentioned project as though it had been issued at the same time and shall be incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original bid documents, this Addendum shall govern and take precedence. BIDDERS MUST SIGN THE ADDENDUM AND SUBMIT IT WITH THEIR BIDS.**

**B. Bidders are hereby notified that they shall make any necessary adjustments in their estimates as a result of this Addendum. It will be construed that each bidder's proposal is submitted with full knowledge of all modifications and supplemental data specified herein.**

Except as described below, the original bid document remains unchanged. The bid documents are modified and/or clarified, as follows:

- 1. Signal plans:** All work related to the traffic signal equipment and poles is removed from the project. Crosswalk and curb ramps are still to be constructed.
- 2. Tree removal:** Trees noted on the plans to be removed at STA 11+50 (two trees) and STA 11+10 (one tree) shall not be removed. These trees shall be protected and remain in place. The mulituse path may be allowed to be narrowed between the two trees at STA 11+50 to all both trees to remain.
- 3. Pipe Size:** There is a discrepancy between the bid tab and plans as to the pipe size. Pipe shall be 15". HDPE is allowed.
- 4. Retaining walls:** The retaining wall shown at STA 9+85 shall be concrete curb. The retaining wall shown at STA 9+91 shall have a brick façade similar to other curvilinear walls in the N Trade St corridor, located at the intersections of N Trade St/Park Center Dr and N Trade St/Matthews Station St (shown below).



If you need further information, please contact Susan Habina Woolard [shwoolard@matthewsnc.gov](mailto:shwoolard@matthewsnc.gov) or 704-708-1243.

**BIDDER MUST ACKNOWLEDGE THIS ADDENDUM BY SIGNING BELOW AND ATTACHING THE SIGNED ADDENDUM TO THE BID FORM:**

---

Company Name \_\_\_\_\_

Contact Person \_\_\_\_\_

Signature \_\_\_\_\_

Date \_\_\_\_\_

**Susan Habina Woolard, PE**  
Town of Matthews Town Engineer